



SREE PADMANABHA SWAMY TEMPLE

MATHILAKAM OFFICE, WEST NADA, FORT, THIRUVANANTHAPURAM – 695023

Phone: 0471 2450233, 2450031; Fax: 0471 2450233

Website: www.spst.in ; E-mails: ospsttvpm@gmail.com ;

mathilakamofficespst@gmail.com

File No: A2/2021/SPST

Date:05.01.2022

Tender Notice

Sealed Tenders are invited for the for the supply, installation, testing and commissioning of Fire alarm system and Fire extinguisher in Sree Padmanabha Swamy Temple, Thiruvananthapuram.

ESTIMATE FOR FIRE EXTINGUISHER AND FIRE ALARM

| Sl.NO | | Unit | Quantity |
|-------|---|------|----------|
| 1. | Fire Extinguisher | | |
| | Supply and installation of ABC Stored Pressure type Dry chemical powder fire extinguisher 4Kg with ISI:14609 mark | NOS | 30 |
| | FIRE EXTINGUISHER CO 2 2 KG | NOS | 4 |
| | FIRE EXTINGUISHER MODULAR TYPE 2KG | NOS | 25 |
| | FIRE EXTINGUISHER TROLLY TYPE 25 KG | NOS | 4 |
| | (Make: ANDEX/SAFE FIRE/and SIMILAR APPROVED) | | |
| 2. | Fire Alarm Panel | | |
| | Supply of automatic fire alarm panel of-8 zones complete with charger, rectifier, alarm display with all other necessary attachments. The panel shall have individual zone with indication for fire for short and isolation facility. Provision for testing each zone separately shall be provided in the panel | NOS | 1 |
| | (Make: AGNI/SIMILAR APPROVED) | | |
| 3. | Smoke Detector | | |
| | Optical smoke detector with remote LED output +base, Dual LED, Blinking type (Ullisted / LPCB Listed) | NOS | 25 |
| | (Make: AGNI/ SYSTEM SENSOR, ANDEX/ SIMILAR APPROVED) | | |
| 4. | Manual Call Points | | |
| | Supply of manual call points with break glass | NOS | 7 |
| | (Make: AGNI/SIMILAR APPROVED) | | |
| 5. | Audio Hooter | | |
| | Supply of audio alarm hooters | NOS | 7 |
| | (Make: AGNI/SIMILAR APPROVED) | | |
| 6. | Conduit | | |
| | Supply and installation of 25mm conduit | RM | 5 |

| | | | |
|----|--|----|-----|
| 7. | Alarm Cable | | |
| | Supply & laying 1.5 X 2 Sq.mm 2 core copper Armoured FRLS LT cable confirming relevant ISI and fire protection laws including termination complete as per specification as required. | RM | 300 |
| | (POLYCAB) or SIMILAR APPROVED | | |

Conditions

1. The tenderer should have done installation works of Fire fighting & detection for Rs 25 lakh or above.
2. The tenderer should have Minimum 5 years of experience in fire fighting and installation.
3. Should submit DD of Rs 3500/- as EMD.
4. Copy of IT and GST returns of 3 years to be submitted.

Interested Companies / Firms who are eligible can apply.

The Last date and time for submission of Tender is 4 pm on 12.01.2022.


EXECUTIVE OFFICER