



SREE PADMANABHA SWAMY TEMPLE

MATHILAKAM OFFICE, WEST NADA, FORT, THIRUVANANTHAPURAM – 695023

Phone: 0471 2450233, 2450031; Fax: 0471 2450233

Website: www.spst.in ; E-mails: eospsttvp@gmail.com ;
mathilakamofficespst@gmail.com

File No: A2/2021/SPST

Date: 05.01.2022

Tender Notice

Sealed Tenders are invited for the for the supply, installation, testing and commissioning of Fire alarm system and Fire extinguisher in Sree Padmanabha Swamy Temple, Thiruvananthapuram.

ESTIMATE FOR FIRE EXTINGUISHER AND FIRE ALARM

1.	Fire Extinguisher		qty
	Supply and installation of ABC Stored Pressure type Dry chemical powder fire extinguisher 4Kg with ISI:14609 mark	NOS	30
	FIRE EXTINGUISHER CO 2 2 KG	NOS	4
	FIRE EXTINGUISHER MODULAR TYPE 2KG	NOS	25
	FIRE EXTINGUISHER TROLLY TYPE 25 KG	NOS	4
	(Make: ANDEX/SAFE FIRE/Havells and SIMILAR APPROVED)		
2.	Fire Alarm Panel		
	Supply of automatic fire alarm panel of 8 zones complete with charger, rectifier, alarm display with all other necessary attachments. The panel shall have individual zone with indication for fire for short and isolation facility. Provision for testing each zone separately shall be provided in the panel	NOS	1
	(Make: AGNI/SIMILAR APPROVED)		
3.	Smoke Detector		
	Optical smoke detector with remote LED output +base, Dual LED, Blinking type (Ullisted / LPCB Listed)	NOS	25
	(Make: AGNI/ SYSTEM SENSOR - ANDEX/ SIMILAR APPROVED)		

4.	Manual Call Points		
	Supply of manual call points with break glass (Make: AGNI/SIMILAR APPROVED)	NOS	7
5.	Audio Hooter		
	Supply of audio alarm hooters (Make: AGNI/SIMILAR APPROVED)	NOS	7
6.	Conduit		
	Supply and installation of 25mm conduit (Make: ISI MARKED)	RM	250
7.	Alarm Cable		
	Supply & laying 1 sq.mm copper conductor PVC insulated fire proof cable confirming relevant ISI and fire protection laws including termination complete as per specification as required. (Make: VILVEX)	RM	1200
8.	Alarm Cable		
	Supply & laying 1.5 X 2 Sq.mm 2 core copper Armoured FRLS LT cable confirming relevant ISI and fire protection laws including termination complete as per specification as required. (Make: POLYCAB or SIMILAR APPROVED)	RM	300

Conditions

1. The tenderer should have done installation works of Fire fighting & detection for Rs 25 lakh or above.
2. The tenderer should have Minimum 5 years of experience in fire fighting and installation.
3. Should submit DD of Rs 3500/- as EMD.
4. Copy of IT and GST returns of 3 years to be submitted.

Interested Companies / Firms who are eligible can apply.

Last date of submitting the tender is 12.01.2022, 4.00pm.


EXECUTIVE OFFICER